



Renewable assets performance management

ONSHORE WIND CASE STUDY – AI DRIVEN

OCTOBER 2022

Agenda

- | | |
|---------------------|----|
| 1. AFRY at a glance | 3 |
| 2. Case Study | 11 |



AFRY AT GLANCE

We are a global engineering, design, and advisory company with 17,000 experts serving clients in more than 100 countries across the globe

AFRY AT A GLANCE

EMPLOYEES GLOBALLY

~ 17,000

(at the end of 2021)

NET SALES

€ 2.0 bn

(in 2021)

NUMBER OF COUNTRIES
WITH OFFICES

> 40

NUMBER OF COUNTRIES
WITH PROJECTS

> 100

AFRY CORE EXPERTISE




Engineering



Design




Digitalisation




Management Consulting


AFRY GROWTH DRIVERS




Infrastructure



Food & Life Science



Clean Energy



Bioindustry

Our organization falls into 6 divisions to bring a unique value proposition of a rare combination of consulting, engineering and digital capabilities



INFRASTRUCTURE

- Transportation
- Buildings
- Water
- Environment



INDUSTRIAL SOLUTIONS

- Advanced Automation
- Automotive R&D
- Experience Design
- Food & Pharma



PROCESS INDUSTRIES

- Pulp & paper
- Mining & Metals
- Steel Industry
- Chemical




ENERGY

- Renewables
- Hydro
- Thermal
- Transmission & Distribution



MGT CONSULTING

- Sustainability
- Operational & Digital transformation
- Market Analysis
- Strategy
- Transaction services



AFRY X

- Digital services
- Digital products
- Artificial intelligence
- Data analytics


Agenda

- | | |
|---------------------------|----|
| 1. AFRY at a glance | 3 |
| 2. Case Study Using e-DAP | 11 |



Assess observed production degradation and explore optimization potential

ASSET OVERVIEW



#Turbines

7

Hub height

80m

Rotor diameter

90m

Total capacity

17.5 MW

Rated power per turbine

2,500 kW

Data history

+6.5 years

CHALLENGES




CONFIDENTIAL

DIFFICULTIES TO ACHIEVE THE PLANNED POWER PRODUCTION:

- 1 ASSESS PRODUCTION DEGRADATION OVER TIME FOR SOME TURBINES AND INVESTIGATE ROOT CAUSES
- 2 EXPLORE PRODUCTION OPTIMIZATION POTENTIAL

AFRY’s multidisciplinary team has leveraged farm data to investigate the challenges, outline improvement potential and associated value

APPROACH

-  **DIGITAL TWIN (ACCURACY: 99%)**
Simulate power production provided weather conditions and operational settings
-  **PRODUCTION DEGRADATION ASSESSMENT**
LOSS DETECTION & ASSESSMENT
-  **PRODUCTION EFFICIENCY (SENSITIVE) ANALYSIS**
POWER PRODUCTION OPTIMIZATION
-  **DAY AHEAD POWER PREDICTION @ FARM LEVEL**
WAKE SIMULATION AND DAY AHEAD POWER PERDITION @ TURBINE LEVEL



OUTCOMES




- 1** Production degradation confirmed

Potential losses for each turbine
Excluding shutdowns and optimization potential
 - ▶ **4 TURBINES**
 - ▶ **3 TO 5%**
(VS FARM: 2,2%)
- 2** Production optimization potential confirmed

Potential optimization for each turbine
Based on operational settings’ optimization, excluding shutdowns and low production period
 - ▶ **3 TURBINES**
 - ▶ **+4,1 TO 7,3%**
(VS FARM 2,3%)
- 3** Improved Day Ahead power Production
Accuracy of prediction based on wake effect vs “Std” prediction (same algorithm)
 - ▶ **+ 4%**

CASE STUDY –CONCLUSIONS

Furthermore, the study has confirmed the status of each turbine and recommended further priorities & investigations to secure the value



APPENDIX 1


Case study results (e-DAP) - Illustration






AFRY's "digital twin" considers both weather information and operational settings to estimate the power production for each turbine. It comes with 99% of accuracy

TURBINE 7 – ACTUAL VS SIMULATED PRODUCTION CORRELATION – $R^2=0,9956$



TURBINE 7 - ACTUAL VS SIMULATED PRODUCTION (KW) – ONE WEEK







PRODUCTION DEGRADATION

A mid-term and long-term assessment confirm the power production degradation over time for 4 turbines


LOW FREQUENCY DEVIATION (1 YEAR MOVING AVG) TURBINE 3,4,5



MEDIUM FREQUENCY DEVIATION (1 QUARTER. MOVING AVG) TURBINE



POWER PRODUCTION DEGRADATION OVER 6 YEARS




Vs a std degradation factor of 0,5 to 10% during the first 10 years of operations




PRODUCTION DECLINE

Turbines with a power production degradation show high losses (value and frequency) that could have been anticipated with predictive maintenance

TURBINE 3 - ACTUAL VS SIMULATED AVERAGE PRODUCTION* (KW)




TURBINE 3 - LOSSES*




- ▶ 4% OF PRODUCTION LOSSES THAT COULD HAVE BEEN ANTICIPATED
- ▶ HIGH LOSSES FREQUENCIES COULD TRIGGER A PREVENTIVE MAINTENANCE ACTION

TURBINE 4 - ACTUAL AND SIMULATED AVERAGE PRODUCTION* (KW)



TURBINE 4 - LOSSES*



*Moving average production (to focus on long term behavior)

*Losses Value > 2 times simulation errors with a duration higher than 3 hours (Excluding shutdown)